## SIEMENS

## Data sheet

## 6AG1511-1AK02-7AB0



SIPLUS S7-1500 CPU 1511-1 PN based on 6ES7511-1AK02-0AB0 with conformal coating, -40...+70 °C, heat sink, no PS usable, central processing unit with work memory 150 KB for program and 1 MB for data, 1st interface: PROFINET IRT with 2-port switch, 60 ns bit performance, SIMATIC Memory Card required spare part display: 6AG1591-1AB00-2AA0

General information	
Product type designation	CPU 1511-1 PN
based on	6ES7511-1AK02-0AB0
Product function	
• I&M data	Yes; I&M0 to I&M3
Isochronous mode	Yes; Distributed and central; with minimum OB 6x cycle of 625 $\mu s$ (distributed) and 1 ms (central)
Engineering with	
<ul> <li>STEP 7 TIA Portal configurable/integrated from version</li> </ul>	see entry ID: 109746275
Configuration control	
via dataset	Yes
Display	
Screen diagonal [cm]	3.45 cm
Control elements	
Number of keys	8
Mode buttons	2
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
Mains/voltage failure stored energy time	5 ms
Repeat rate, min.	1/s
Input current	
Current consumption (rated value)	0.7 A
Current consumption, max.	0.95 A
Inrush current, max.	1.9 A; Rated value
l²t	0.02 A <sup>2</sup> ·s
Power	
Infeed power to the backplane bus	10 W
Power consumption from the backplane bus (balanced)	5.5 W
Power loss	
Power loss, typ.	5.7 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
• integrated (for program)	150 kbyte
<ul> <li>integrated (for data)</li> </ul>	1 Mbyte

Load memory	
Plug-in (SIMATIC Memory Card), max.	32 Gbyte
Backup	
maintenance-free	Yes
CPU processing times	100
for bit operations, typ.	60 ns
for word operations, typ.	72 ns
	96 ns
for fixed point arithmetic, typ for floating point arithmetic, typ.	384 ns
CPU-blocks	304 115
Number of elements (total)	2 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
	1 60,000; subdivided into: number range that can be used by the user: 1
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	1 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	
Number range	0 65 535
• Size, max.	150 kbyte
FC	
Number range	0 65 535
• Size, max.	150 kbyte
OB	
• Size, max.	150 kbyte
Number of free cycle OBs	100
Number of time alarm OBs	20
Number of delay alarm OBs	20
Number of cyclic interrupt OBs	20; With minimum OB 3x cycle of 500 µs
Number of process alarm OBs	50
Number of DPV1 alarm OBs	3
Number of isochronous mode OBs	2
Number of technology synchronous alarm OBs	2
Number of startup OBs	100
Number of asynchronous error OBs	4
Number of synchronous error OBs	2
Number of diagnostic alarm OBs	- 1
Nesting depth	
per priority class	24
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	2010
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
Data areas and their retentivity	
	120 khuto: In total: available estantive memory for hit memories timere
Retentive data area (incl. timers, counters, flags), max.	128 kbyte; In total; available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 88 KB
Flag	
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	

Retentivity adjustable	Yes			
Retentivity augustable	No			
Local data	NO			
per priority class, max.	64 kbyte; max. 16 KB per block			
Address area				
Number of IO modules	1 024; max. number of modules / submodules			
I/O address area				
Inputs	32 kbyte; All inputs are in the process image			
Outputs	32 kbyte; All outputs are in the process image			
per integrated IO subsystem				
— Inputs (volume)	8 kbyte			
— Outputs (volume)	8 kbyte			
per CM/CP				
— Inputs (volume)	8 kbyte			
— Outputs (volume)	8 kbyte			
Subprocess images				
<ul> <li>Number of subprocess images, max.</li> </ul>	32			
Hardware configuration				
Number of distributed IO systems	32; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)			
Number of DP masters				
• Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total			
Number of IO Controllers				
<ul> <li>integrated</li> </ul>	1			
• Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be			
Deck	inserted in total			
Rack	32; CPU + 31 modules; no system power supply (PS) can be used			
<ul> <li>Modules per rack, max.</li> <li>Number of lines, max.</li> </ul>	1			
PtP CM				
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots			
Time of day				
Clock				
• Туре	Hardware clock			
Backup time	6 wk; At 40 °C ambient temperature, typically			
<ul> <li>Deviation per day, max.</li> </ul>	10 s; Typ.: 2 s			
Operating hours counter				
Number	16			
Clock synchronization				
• supported	Yes			
• in AS, master	Yes			
• in AS, device	Yes			
on Ethernet via NTP	Yes			
Interfaces	1			
Number of PROFINET interfaces	1			
1. Interface				
Interface types				
RI45 (Ethernet)	Ves: X1			
RJ 45 (Ethernet)     Number of ports	Yes; X1			
Number of ports	2			
<ul><li>Number of ports</li><li>integrated switch</li></ul>				
Number of ports     integrated switch Protocols	2 Yes			
Number of ports     integrated switch Protocols     IP protocol	2 Yes Yes; IPv4			
Number of ports     integrated switch  Protocols      IP protocol      PROFINET IO Controller	2 Yes Yes; IPv4 Yes			
Number of ports     integrated switch  Protocols      IP protocol      PROFINET IO Controller      PROFINET IO Device	2 Yes Yes; IPv4 Yes Yes			
Number of ports     integrated switch  Protocols      IP protocol      PROFINET IO Controller      PROFINET IO Device      SIMATIC communication	2 Yes Yes; IPv4 Yes Yes Yes			
<ul> <li>Number of ports</li> <li>integrated switch</li> <li>Protocols</li> <li>PROFINET IO Controller</li> <li>PROFINET IO Device</li> <li>SIMATIC communication</li> <li>Open IE communication</li> </ul>	2 Yes Yes; IPv4 Yes Yes Yes Yes Yes Yes; Optionally also encrypted			
Number of ports     integrated switch  Protocols      IP protocol      PROFINET IO Controller      PROFINET IO Device      SIMATIC communication	2 Yes Yes; IPv4 Yes Yes Yes			

Services	
— PG/OP communication	Yes
— Isochronous mode	Yes
— Direct data exchange	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
— Prioritized startup	Yes; Max. 32 PROFINET devices
- Number of connectable IO Devices, max.	128; In total, up to 256 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
— Of which IO devices with IRT, max.	64
<ul> <li>— Number of connectable IO Devices for RT, max.</li> </ul>	128
— of which in line, max.	128
<ul> <li>— Number of IO Devices that can be simultaneously activated/deactivated, max.</li> </ul>	8; in total across all interfaces
- Number of IO Devices per tool, max.	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 250 µs	250 $\mu s$ to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 $\mu s$ of the isochronous OB is decisive
— for send cycle of 500 μs	500 $\mu s$ to 8 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 $\mu s$ of the isochronous OB is decisive
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
— With IRT and parameterization of "odd" send cycles	Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)
Update time for RT	
— for send cycle of 250 µs	250 µs to 128 ms
— for send cycle of 500 μs	500 µs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
<ul> <li>— Isochronous mode</li> </ul>	No
— IRT	Yes
— PROFlenergy	Yes; per user program
— Shared device	Yes
- Number of IO Controllers with shared device, max.	4
<ul> <li>Asset management record</li> </ul>	Yes; per user program
Interface types	
RJ 45 (Ethernet)	
• 100 Mbps	Yes
Autonegotiation	Yes
Autocrossing	Yes
Industrial Ethernet status LED	Yes
Protocols	
PROFIsafe	No
Number of connections	
Number of connections, max.	96; via integrated interfaces of the CPU and connected CPs / CMs
Number of connections reserved for ES/HMI/web	10
Number of connections via integrated interfaces	64
Number of S7 routing paths	16
Redundancy mode	
H-Sync forwarding	Yes
Media redundancy	
- MRP	Yes; as MRP redundancy manager and/or MRP client; max. number of devices in the ring: 50
— MRPD	Yes; Requirement: IRT
— Switchover time on line break, typ.	200 ms; For MRP, bumpless for MRPD

- Number of stations in the ring, max.	50		
SIMATIC communication	30		
S7 routing	Yes		
S7 communication, as server	Yes		
S7 communication, as client	Yes		
• User data per job, max.	See online help (S7 communication, user data size)		
Open IE communication			
• TCP/IP	Yes		
— Data length, max.	64 kbyte		
- several passive connections per port, supported	Yes		
<ul> <li>ISO-on-TCP (RFC1006)</li> </ul>	Yes		
— Data length, max.	64 kbyte		
• UDP	Yes		
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast		
— UDP multicast	Yes; Max. 5 multicast circuits		
• DHCP	No		
• SNMP	Yes		
• DCP	Yes		
• LLDP	Yes		
Web server			
• HTTP	Yes; Standard and user pages		
• HTTPS	Yes; Standard and user pages		
OPC UA   Runtime license required	Yes		
OPC UA Client	Yes		
Application authentication	Yes		
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15,		
	Basic256Sha256		
— User authentication	"anonymous" or by user name & password		
- Number of connections, max.	4		
<ul> <li>— Number of nodes of the client interfaces, recommended max.</li> </ul>	1 000		
<ul> <li>— Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/OPC_L max.</li> </ul>	300		
<ul> <li>— Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max.</li> </ul>	20		
<ul> <li>— Number of elements for one call of OPC_UA_MethodGetHandleList, max.</li> </ul>	100		
<ul> <li>Number of simultaneous calls of the client instructions for session management, per connection, max.</li> </ul>	1		
<ul> <li>— Number of simultaneous calls of the client instructions for data access, per connection, max.</li> </ul>	5		
- Number of registerable nodes, max.	5 000		
<ul> <li>— Number of registerable method calls of OPC_UA_MethodCall, max.</li> </ul>	100		
<ul> <li>— Number of inputs/outputs when calling OPC_UA_MethodCall, max.</li> </ul>	20		
OPC UA Server	Yes; Data access (read, write, subscribe), method call, custom address space		
<ul> <li>Application authentication</li> </ul>	Yes		
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256		
— User authentication	"anonymous" or by user name & password		
— Number of sessions, max.	32		
<ul> <li>Number of accessible variables, max.</li> </ul>	50 000		
<ul> <li>Number of registerable nodes, max.</li> </ul>	10 000		
<ul> <li>Number of subscriptions per session, max.</li> </ul>	20		
— Sampling interval, min.	100 ms		
— Publishing interval, min.	500 ms		
<ul> <li>Number of server methods, max.</li> </ul>	20		
<ul> <li>Number of inputs/outputs per server method, max.</li> </ul>	20		
<ul> <li>— Number of monitored items, recommended max.</li> <li>— Number of server interfaces, max.</li> </ul>	1 000; for 1 s sampling interval and 1 s send interval 10; or 20, depending on type of server interface		

Number of nodes for user-defined server interfaces,	1 000
max. Further protocols	
MODBUS	
	Yes; MODBUS TCP
Isochronous mode	No.
Equidistance	Yes
S7 message functions	
Number of login stations for message functions, max.	32
Program alarms	Yes
Number of configurable program messages, max.	5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
Number of loadable program messages in RUN, max.	2 500
Number of simultaneously active program alarms	
<ul> <li>Number of program alarms</li> </ul>	300
<ul> <li>Number of alarms for system diagnostics</li> </ul>	100
<ul> <li>Number of alarms for motion technology objects</li> </ul>	80
Test commissioning functions	
Joint commission (Team Engineering)	Yes; Parallel online access possible for up to 5 engineering systems
Status block	Yes; Up to 8 simultaneously (in total across all ES clients)
Single step	No
Number of breakpoints	8
Status/control	
Status/control variable	Yes
Variables	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
• Number of variables, max.	
— of which status variables, max.	200; per job
— of which control variables, max.	200; per job
Forcing	
<ul> <li>Forcing, variables</li> </ul>	Peripheral inputs/outputs
Number of variables, max.	200
Diagnostic buffer	
• present	Yes
Number of entries, max.	1 000
— of which powerfail-proof	500
Traces	
Number of configurable Traces	4; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	Yele a second
Diagnostics indication LED	
RUN/STOP LED	Yes
ERROR LED	Yes
ERROR LED     MAINT LED	Yes
MAINT LED     STOP ACTIVE LED	
	Yes
Connection display LINK TX/RX	Yes
Supported technology objects	
Motion Control	Yes; Note: The number of axes affects the cycle time of the PLC program; selection guide via the TIA Selection Tool or SIZER
<ul> <li>Number of available Motion Control resources for technology objects</li> </ul>	800
Required Motion Control resources	
-	40
— per speed-controlled axis	40
— per positioning axis	80
— per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
a sa sa sa b s	40
— per probe	40
Positioning axis	
<ul> <li>Positioning axis</li> <li>— Number of positioning axes at motion control cycle of 4 ms (typical value)</li> </ul>	5
<ul> <li>Positioning axis</li> <li>— Number of positioning axes at motion control cycle</li> </ul>	

- PID. Compact	Vac: Universal PID controller with integrated entimization		
PID_Compact	Yes; Universal PID controller with integrated optimization		
PID_3Step	Yes; PID controller with integrated optimization for valves		
PID-Temp	Yes; PID controller with integrated optimization for temperature		
Counting and measuring	Vee		
High-speed counter	Yes		
Ambient conditions			
Ambient temperature during operation	40 °C: Train (inclusion dans after (faret))		
horizontal installation, min.	-40 °C; = Tmin (incl. condensation/frost)		
horizontal installation, max.	70 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off		
• vertical installation, min.	-40 °C; = Tmin (incl. condensation/frost)		
<ul> <li>vertical installation, max.</li> </ul>	40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off		
Ambient temperature during storage/transportation			
• min.	-40 °C		
• max.	70 °C		
Altitude during operation relating to sea level			
Installation altitude above sea level, max.	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual		
Ambient air temperature-barometric pressure-altitude	Restrictions for installation altitudes > $2000 \text{ m}$ , see entry ID: 109763260		
Relative humidity			
With condensation, tested in accordance with IEC 60068- 2-38, max.	100 %; RH incl. condensation / frost (no commissioning in bedewed state), horizontal installation		
Resistance			
Coolants and lubricants			
<ul> <li>Resistant to commercially available coolants and lubricants</li> </ul>	Yes; Incl. diesel and oil droplets in the air		
Use in stationary industrial systems			
— to biologically active substances according to EN     60721-3-3	Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request		
— to chemically active substances according to EN 60721-3-3	Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *		
<ul> <li>to mechanically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3S4 incl. sand, dust, *		
Use on ships/at sea			
<ul> <li>— to biologically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6B2 mold, fungal and dry rot spores (excluding fauna)		
<ul> <li>— to chemically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *		
<ul> <li>— to mechanically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6S3 incl. sand, dust; *		
Usage in industrial process technology			
— Against chemically active substances acc. to EN 60654-4	Yes; Class 3 (excluding trichlorethylene)		
<ul> <li>Environmental conditions for process, measuring and control systems acc. to ANSI/ISA-71.04</li> </ul>	Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil)		
Remark			
<ul> <li>Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04</li> </ul>	* The supplied plug covers must remain in place over the unused interfaces during operation!		
Conformal coating			
Coatings for printed circuit board assemblies acc. to EN     61086	Yes; Class 2 for high reliability		
<ul> <li>Protection against fouling acc. to EN 60664-3</li> </ul>	Yes; Type 1 protection		
Military testing according to MIL-I-46058C, Amendment 7	Yes; Discoloration of coating possible during service life		
Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC- CC-830A	Yes; Conformal coating, Class A		
configuration / header			
configuration / programming / header			
Programming language			
— LAD	Yes		
— LAD — FBD	Yes Yes		
— FBD	Yes		

Know-how protection			
<ul> <li>User program protection/password protection</li> </ul>	Yes		
Copy protection	Yes		
<ul> <li>Block protection</li> </ul>	Yes		
Access protection			
<ul> <li>Password for display</li> </ul>	Yes		
<ul> <li>Protection level: Write protection</li> </ul>	Yes		
<ul> <li>Protection level: Read/write protection</li> </ul>	Yes		
<ul> <li>Protection level: Complete protection</li> </ul>	Yes		
programming / cycle time monitoring / header			
lower limit	adjustable minimum cycle time		
• upper limit	adjustable maximum cycle time		
imensions			
Width	70 mm		
Height	147 mm		
Depth	129 mm		
leights		_	
Weight, approx.	590 g		
lassifications		Version	Classification
	eClass	14	27-24-22-07
	eClass	12	27-24-22-07
	eClass	9.1	27-24-22-07
	eClass	9	27-24-22-07
	eClass	8	27-24-22-07
	eClass	7.1	27-24-22-07
	eClass	6	27-24-22-07
	ETIM	9	EC000236
	ETIM	8	EC000236
	ETIM	7	EC000236
	IDEA	4	3565
	UNSPSC	15	32-15-17-05
pprovals / Certificates		10	02 10 11 00
General Product Approval			EMV
Miscellaneous Manufacturer Declara-		ŝ	A
tion		(ŸL)	<u>/</u> \(\)
	EG-Konf.	UL	RCM
For use in hazardous locations			
ATEX			
- 17 Berlin P			
	10/0/07 · C <b>R</b>		
ast modified:	12/8/2024 🖸		