## SIEMENS

## Data sheet

## 6AG1518-4FP00-4AB0



SIPLUS S7-1500 CPU 1518F-4 PN/DP based on 6ES7518-4FP00-0AB0 with conformal coating, 0...+60 °C, central processing unit with work memory 4.5 MB for program and 10 MB for data, 1st interface: PROFINET IRT with 2-port switch, 2nd interface, Ethernet, 3rd interface, Ethernet, 4th interface, PROFIBUS, 1 ns bit performance, SIMATIC Memory Card required

General information	
Product type designation	CPU 1518F-4PN/DP
Product function	
• I&M data	Yes; I&M0 to I&M3
Isochronous mode	Yes; Distributed and central; with minimum OB 6x cycle of 125 $\mu s$ (distributed) and 1 ms (central)
Engineering with	
<ul> <li>STEP 7 TIA Portal configurable/integrated from version</li> </ul>	see entry ID: 109746275
Configuration control	
via dataset	Yes
Display	
Screen diagonal [cm]	6.1 cm
Control elements	
Number of keys	6
Mode selector switch	1
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
<ul> <li>Mains/voltage failure stored energy time</li> </ul>	5 ms
Repeat rate, min.	1/s
Input current	
Current consumption (rated value)	1.55 A
Inrush current, max.	2.4 A; Rated value
	0.02 A <sup>2</sup> ·s
Power	
Infeed power to the backplane bus	12 W
Power consumption from the backplane bus (balanced)	30 W
Power loss	
Power loss, typ.	24 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
<ul> <li>integrated (for program)</li> </ul>	9 Mbyte
<ul> <li>integrated (for data)</li> </ul>	60 Mbyte
Load memory	
<ul> <li>Plug-in (SIMATIC Memory Card), max.</li> </ul>	32 Gbyte

Backup	
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	1 ns
for word operations, typ.	2 ns
	2 ns
for fixed point arithmetic, typ.	
for floating point arithmetic, typ.	6 ns
CPU-blocks	
Number of elements (total)	20 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	16 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	To moyte, Tor DDs with absolute addressing, the max. size is 04 ND
	0 65 535
Number range	
• Size, max. FC	1 Mbyte
	0 05 525
Number range	0 65 535
• Size, max.	1 Mbyte
OB	
• Size, max.	1 Mbyte
Number of free cycle OBs	100
Number of time alarm OBs	20
<ul> <li>Number of delay alarm OBs</li> </ul>	20
Number of cyclic interrupt OBs	20; with minimum OB 3x cycle of 100 µs
<ul> <li>Number of process alarm OBs</li> </ul>	50
<ul> <li>Number of DPV1 alarm OBs</li> </ul>	3
<ul> <li>Number of isochronous mode OBs</li> </ul>	3
<ul> <li>Number of technology synchronous alarm OBs</li> </ul>	2
<ul> <li>Number of startup OBs</li> </ul>	100
<ul> <li>Number of asynchronous error OBs</li> </ul>	4
<ul> <li>Number of synchronous error OBs</li> </ul>	2
<ul> <li>Number of diagnostic alarm OBs</li> </ul>	1
Nesting depth	
• per priority class	24
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
• Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
Number	2 048
	2 046
Retentivity	Vee
— adjustable	Yes
IEC timer	
• Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	768 kbyte; In total; available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 700 KB
Extended retentive data area (incl. timers, counters, flags), max.	20 Mbyte; When using PS 6 0W 24/48/60 V DC HF
Flag	
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	
Retentivity adjustable	Yes

Retentivity preset	No
Local data	NO
	64 kbyte; max. 16 KB per block
per priority class, max.  Address area	04 kbyte, max. To KB per block
	40.004 ment autobas of modules ( automotivies
Number of IO modules	16 384; max. number of modules / submodules
I/O address area	20 libute: All insulta are in the process image
Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	32 kbyte; max. 32 KB via X1; max. 8 KB via X2 or X4
— Outputs (volume)	32 kbyte; max. 32 KB via X1; max. 8 KB via X2 or X4
per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	
Number of subprocess images, max.	32
Hardware configuration	
Number of distributed IO systems	64; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
<ul> <li>integrated</li> </ul>	1
• Via CM	8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be
	inserted in total
Number of IO Controllers	
<ul> <li>integrated</li> </ul>	2
• Via CM	8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Rack	
Modules per rack, max.	32; CPU + 31 modules
Number of lines, max.	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Number of PtP CMs	
Number of PtP CMs Time of day	
Number of PtP CMs Time of day Clock	slots
Number of PtP CMs Time of day Clock     Type	slots Hardware clock
Number of PtP CMs Time of day Clock     Type     Backup time	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically
Number of PtP CMs Time of day Clock     Type     Backup time     Deviation per day, max.	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically
Number of PtP CMs Time of day Clock     Type     Backup time     Deviation per day, max. Operating hours counter	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s
Number of PtP CMs Time of day Clock     Type     Backup time     Deviation per day, max. Operating hours counter     Number	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s
Number of PtP CMs  Time of day  Clock      Type      Backup time      Deviation per day, max.  Operating hours counter      Number  Clock synchronization	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16
Number of PtP CMs Time of day Clock     Type     Backup time     Deviation per day, max. Operating hours counter     Number Clock synchronization     supported	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 Yes
Number of PtP CMs Time of day Clock     Type     Backup time     Deviation per day, max. Operating hours counter     Number Clock synchronization     supported     to DP, master	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 Yes Yes
Number of PtP CMs  Time of day  Clock      Type      Backup time      Deviation per day, max.  Operating hours counter      Number  Clock synchronization      supported      to DP, master      in AS, master	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 Yes Yes Yes
<ul> <li>Number of PtP CMs</li> <li>Time of day</li> <li>Clock <ul> <li>Type</li> <li>Backup time</li> <li>Deviation per day, max.</li> </ul> </li> <li>Operating hours counter <ul> <li>Number</li> </ul> </li> <li>Clock synchronization <ul> <li>supported</li> <li>to DP, master</li> <li>in AS, master</li> <li>in AS, device</li> </ul> </li> </ul>	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 Yes Yes Yes Yes Yes Yes Yes
<ul> <li>Number of PtP CMs</li> <li>Time of day</li> <li>Clock <ul> <li>Type</li> <li>Backup time</li> <li>Deviation per day, max.</li> </ul> </li> <li>Operating hours counter <ul> <li>Number</li> </ul> </li> <li>Clock synchronization <ul> <li>supported</li> <li>to DP, master</li> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul> </li> </ul>	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 Yes Yes Yes Yes Yes Yes Yes
<ul> <li>Number of PtP CMs</li> <li>Time of day</li> <li>Clock <ul> <li>Type</li> <li>Backup time</li> <li>Deviation per day, max.</li> </ul> </li> <li>Operating hours counter <ul> <li>Number</li> </ul> </li> <li>Clock synchronization <ul> <li>supported</li> <li>to DP, master</li> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul> </li> <li>Interfaces</li> </ul>	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 Yes Yes Yes Yes Yes Yes Yes Yes
Number of PtP CMs  Time of day  Clock      Type     Backup time     Deviation per day, max.  Operating hours counter     Number  Clock synchronization     supported     to DP, master     in AS, master     in AS, device     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 Yes
Number of PtP CMs  Time of day  Clock      Type     Backup time     Deviation per day, max.  Operating hours counter     Number  Clock synchronization     supported     to DP, master     in AS, master     in AS, device     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 Yes
Number of PtP CMs      Time of day      Clock          Type         Backup time         Deviation per day, max.      Operating hours counter         Number      Clock synchronization          supported         to DP, master         in AS, master         in AS, device         o on Ethernet via NTP  Interfaces  Number of PROFIBUS interfaces  Number of PROFIBUS interfaces  I. Interface Interface types	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 Yes
<ul> <li>Number of PtP CMs</li> <li>Time of day</li> <li>Clock <ul> <li>Type</li> <li>Backup time</li> <li>Deviation per day, max.</li> </ul> </li> <li>Operating hours counter <ul> <li>Number</li> </ul> </li> <li>Clock synchronization</li> <li>supported</li> <li>to DP, master</li> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul> <li>Interfaces <ul> <li>Number of PROFINET interfaces</li> <li>Number of PROFIBUS interfaces</li> <li>Interface types</li> <li>RJ 45 (Ethernet)</li> </ul> </li>	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 Yes Yes Yes Yes Yes Yes 1 1
<ul> <li>Number of PtP CMs</li> <li>Time of day</li> <li>Clock <ul> <li>Type</li> <li>Backup time</li> <li>Deviation per day, max.</li> </ul> </li> <li>Operating hours counter <ul> <li>Number</li> </ul> </li> <li>Clock synchronization</li> <li>supported</li> <li>to DP, master</li> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul> <li>Interfaces <ul> <li>Number of PROFINET interfaces</li> <li>Number of PROFIBUS interfaces</li> </ul> </li> <li>Interface types <ul> <li>RJ 45 (Ethernet)</li> <li>Number of ports</li> </ul> </li>	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
<ul> <li>Number of PtP CMs</li> <li>Time of day</li> <li>Clock <ul> <li>Type</li> <li>Backup time</li> <li>Deviation per day, max.</li> </ul> </li> <li>Operating hours counter <ul> <li>Number</li> </ul> </li> <li>Clock synchronization <ul> <li>supported</li> <li>to DP, master</li> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul> </li> <li>Interfaces <ul> <li>Number of PROFINET interfaces</li> <li>Number of PROFIBUS interfaces</li> <li>Interface types</li> <li>RJ 45 (Ethernet)</li> <li>Number of ports</li> <li>integrated switch</li> </ul> </li> </ul>	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s  16 Yes
<ul> <li>Number of PtP CMs</li> <li>Time of day</li> <li>Clock <ul> <li>Type</li> <li>Backup time</li> <li>Deviation per day, max.</li> </ul> </li> <li>Operating hours counter <ul> <li>Number</li> </ul> </li> <li>Clock synchronization</li> <li>supported</li> <li>to DP, master</li> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul> <li>Interfaces <ul> <li>Number of PROFINET interfaces</li> <li>Number of PROFIBUS interfaces</li> <li>Interface types</li> <li>RJ 45 (Ethernet)</li> <li>Number of ports</li> <li>integrated switch</li> </ul> </li>	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 16 Yes
<ul> <li>Number of PtP CMs</li> <li>Time of day</li> <li>Clock <ul> <li>Type</li> <li>Backup time</li> <li>Deviation per day, max.</li> </ul> </li> <li>Operating hours counter <ul> <li>Number</li> </ul> </li> <li>Clock synchronization</li> <li>supported</li> <li>to DP, master</li> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul> <li>Interfaces <ul> <li>Number of PROFINET interfaces</li> <li>Number of PROFIBUS interfaces</li> </ul> </li> <li>Interface types <ul> <li>RJ 45 (Ethernet)</li> <li>Number of ports</li> <li>integrated switch</li> </ul> </li>	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 16 Yes
<ul> <li>Number of PtP CMs</li> <li>Time of day</li> <li>Clock <ul> <li>Type</li> <li>Backup time</li> <li>Deviation per day, max.</li> </ul> </li> <li>Operating hours counter <ul> <li>Number</li> </ul> </li> <li>Clock synchronization</li> <li>supported</li> <li>to DP, master</li> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul> <li>Interfaces <ul> <li>Number of PROFINET interfaces</li> <li>Number of PROFIBUS interfaces</li> </ul> </li> <li>Interface types <ul> <li>RJ 45 (Ethernet)</li> <li>Number of ports</li> <li>integrated switch</li> </ul> </li> <li>Protocols <ul> <li>IP protocol</li> <li>PROFINET IO Controller</li> </ul> </li>	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 16 Yes
<ul> <li>Number of PtP CMs</li> <li>Time of day</li> <li>Clock <ul> <li>Type</li> <li>Backup time</li> <li>Deviation per day, max.</li> </ul> </li> <li>Operating hours counter <ul> <li>Number</li> </ul> </li> <li>Clock synchronization</li> <li>supported</li> <li>to DP, master</li> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul> <li>Interfaces <ul> <li>Number of PROFINET interfaces</li> <li>Number of PROFIBUS interfaces</li> </ul> </li> <li>Interface types <ul> <li>RJ 45 (Ethernet)</li> <li>Number of ports</li> <li>integrated switch</li> </ul> </li> <li>Protocols <ul> <li>IP protocol</li> <li>PROFINET IO Controller</li> <li>PROFINET IO Device</li> </ul> </li>	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 16 Yes
<ul> <li>Number of PtP CMs</li> <li>Time of day</li> <li>Clock <ul> <li>Type</li> <li>Backup time</li> <li>Deviation per day, max.</li> </ul> </li> <li>Operating hours counter <ul> <li>Number</li> </ul> </li> <li>Clock synchronization</li> <li>supported</li> <li>to DP, master</li> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul> <li>Interfaces <ul> <li>Number of PROFINET interfaces</li> <li>Number of PROFIBUS interfaces</li> </ul> </li> <li>Interface types <ul> <li>RJ 45 (Ethernet)</li> <li>Number of ports</li> <li>integrated switch</li> </ul> </li> <li>Protocols <ul> <li>IP protocol</li> <li>PROFINET IO Controller</li> <li>PROFINET IO Device</li> <li>SIMATIC communication</li> </ul> </li>	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 16 Yes
<ul> <li>Number of PtP CMs</li> <li>Time of day</li> <li>Clock <ul> <li>Type</li> <li>Backup time</li> <li>Deviation per day, max.</li> </ul> </li> <li>Operating hours counter <ul> <li>Number</li> </ul> </li> <li>Clock synchronization</li> <li>supported</li> <li>to DP, master</li> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul> <li>Interfaces <ul> <li>Number of PROFINET interfaces</li> <li>Number of PROFIBUS interfaces</li> </ul> </li> <li>Interface types <ul> <li>RJ 45 (Ethernet)</li> <li>Number of ports</li> <li>integrated switch</li> </ul> </li> <li>Protocols <ul> <li>IP protocol</li> <li>PROFINET IO Controller</li> <li>PROFINET IO Device</li> </ul> </li>	slots Hardware clock 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s 16 16 Yes

Yes; MRP Automanager according to IEC 62439-2 Edition 2.0

<ul> <li>Media redundancy</li> </ul>	
PROFINET IO Controller	

PROFINET IO Controller	
Services	
— PG/OP communication	Yes
<ul> <li>Isochronous mode</li> </ul>	Yes
— Direct data exchange	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
— Prioritized startup	Yes; Max. 32 PROFINET devices
- Number of connectable IO Devices, max.	512; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
— Of which IO devices with IRT, max.	64
- Number of connectable IO Devices for RT, max.	512
— of which in line, max.	512
<ul> <li>Number of IO Devices that can be simultaneously activated/deactivated, max.</li> </ul>	8; in total across all interfaces
- Number of IO Devices per tool, max.	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 125 μs	125 µs
— for send cycle of 187.5 μs	187.5 µs
— for send cycle of 250 µs	250 µs to 4 ms
— for send cycle of 500 μs	500 µs to 8 ms
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
— With IRT and parameterization of "odd" send cycles	Update time = set "odd" send clock (any multiple of 125 $\mu s$ : 375 $\mu s$ , 625 $\mu s$ 3 875 $\mu s)$
Update time for RT	
— for send cycle of 250 μs	250 µs to 128 ms
— for send cycle of 500 µs	500 µs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— IRT	Yes; Minimum send cycle of 250 µs
— PROFlenergy	Yes; per user program
— Shared device	Yes
<ul> <li>— Number of IO Controllers with shared device, max.</li> </ul>	4
- activation/deactivation of I-devices	Yes; per user program
— Asset management record	Yes; per user program
2. Interface	
Interface types	
RJ 45 (Ethernet)	Yes; X2
Number of ports	1
integrated switch	No
Protocols	
IP protocol	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
SIMATIC communication	Yes
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
Media redundancy	No
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
	1 60

— Isochronous mode	No
— Direct data exchange	No
— Direct data exchange — IRT	No
- PROFlenergy	Yes; per user program No
Prioritized startup	
— Number of connectable IO Devices, max.	128; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
<ul> <li>Number of connectable IO Devices for RT, max.</li> </ul>	128
— of which in line, max.	128
<ul> <li>— Number of IO Devices that can be simultaneously activated/deactivated, max.</li> </ul>	8; in total across all interfaces
— Number of IO Devices per tool, max.	8
— Updating times	The minimum value of the update time also depends on communication share
	set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for RT	
— for send cycle of 1 ms	1 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— IRT	No
- PROFlenergy	Yes; per user program
— Prioritized startup	No
— Shared device	Yes
- Number of IO Controllers with shared device, max.	4
- activation/deactivation of I-devices	Yes; per user program
<ul> <li>Asset management record</li> </ul>	Yes; per user program
3. Interface	
Interface types	
RJ 45 (Ethernet)	Yes; X3
Number of ports	1
integrated switch	No
Protocols	
IP protocol	Yes; IPv4
PROFINET IO Controller	No
PROFINET IO Device	No
SIMATIC communication	Yes
Open IE communication	Yes
Web server	Yes
4. Interface	
Interface types	
• RS 485	Yes; X4
Number of ports	1
Protocols	
PROFIBUS DP master	Yes
PROFIBUS DP device	No
SIMATIC communication	Yes
PROFIBUS DP master	
<ul> <li>Number of connections, max.</li> </ul>	48; for the integrated PROFIBUS DP interface
• max. number of DP devices	125; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
Services	
— PG/OP communication	Yes
— Equidistance	Yes
— Isochronous mode	Yes
- activation/deactivation of DP devices	Yes
Interface types	
RJ 45 (Ethernet)	
• 100 Mbps	Yes
• 1000 Mbps	Yes; Only possible at the X3 interface of the CPU 1518
Autonegotiation	Yes

Autocrossing	Yes
Autocrossing     Industrial Ethernet status LED	Yes
RS 485	
Transmission rate, max.	12 Mbit/s
Protocols	12 Mbito
PROFIsafe	Yes; V2.4 / V2.6
Number of connections	100, V2.47 V2.0
Number of connections, max.	384; via integrated interfaces of the CPU and connected CPs / CMs
Number of connections reserved for ES/HMI/web	10
Number of connections via integrated interfaces	320
Number of S7 routing paths	64; in total, only 16 S7-Routing connections are supported via PROFIBUS
Redundancy mode	
H-Sync forwarding	Yes
Media redundancy	
— Media redundancy	only via 1st interface (X1)
- MRP	Yes; as MRP redundancy manager and/or MRP client
- MRP interconnection, supported	Yes; as ring node according to IEC 62439-2 Edition 2.0
— MRPD	Yes; Requirement: IRT
— Switchover time on line break, typ.	200 ms; For MRP, bumpless for MRPD
- Number of stations in the ring, max.	50
SIMATIC communication	
• S7 routing	Yes
Data record routing	Yes
S7 communication, as server	Yes
S7 communication, as client	Yes
• User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
- several passive connections per port, supported	Yes
ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; 128 multicast circuits (of which max. 5 via X1)
• DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Encryption	Yes; Optional
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	
Runtime license required	Yes
OPC UA Client	Yes
- Application authentication	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	"anonymous" or by user name & password
- Number of connections, max.	40
<ul> <li>— Number of nodes of the client interfaces, recommended max.</li> </ul>	5 000
— Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/OPC_U max.	300
<ul> <li>— Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max.</li> </ul>	20
<ul> <li>— Number of elements for one call of OPC_UA_MethodGetHandleList, max.</li> </ul>	100
<ul> <li>Number of simultaneous calls of the client instructions for session management, per connection,</li> </ul>	1

max.	
— Number of simultaneous calls of the client	5
instructions for data access, per connection, max.	
<ul> <li>Number of registerable nodes, max.</li> </ul>	5 000
- Number of registerable method calls of	100
OPC_UA_MethodCall, max.	20
<ul> <li>— Number of inputs/outputs when calling OPC_UA_MethodCall, max.</li> </ul>	20
• OPC UA Server	Yes; Data access (read, write, subscribe), method call, custom address space
- Application authentication	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	"anonymous" or by user name & password
<ul> <li>Number of sessions, max.</li> </ul>	64
<ul> <li>Number of accessible variables, max.</li> </ul>	200 000
<ul> <li>Number of registerable nodes, max.</li> </ul>	50 000
- Number of subscriptions per session, max.	20
— Sampling interval, min.	10 ms
— Publishing interval, min.	10 ms
- Number of server methods, max.	100
<ul> <li>Number of inputs/outputs per server method, max.</li> </ul>	
<ul> <li>Number of monitored items, recommended max.</li> </ul>	10 000; for 1 s sampling interval and 1 s send interval
<ul> <li>Number of server interfaces, max.</li> </ul>	10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"
<ul> <li>— Number of nodes for user-defined server interfaces, max.</li> </ul>	30 000
Alarms and Conditions	
— Number of program alarms	400
— Number of alarms for system diagnostics	200
Further protocols	
MODBUS	Yes; MODBUS TCP
Isochronous mode	
Equidistance	Yes
Equidistance S7 message functions	res
·	Yes 64
S7 message functions	
S7 message functions Number of login stations for message functions, max.	64
S7 message functions Number of login stations for message functions, max. Program alarms	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block,
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects         Test commissioning functions	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects         Test commissioning functions         Joint commission (Team Engineering)	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects         Test commission (Team Engineering)         Status block	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients)
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects         Test commissioning functions         Joint commission (Team Engineering)         Status block         Single step	64         Yes         10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH         5 000         4 000         1 000         480         Yes; Parallel online access possible for up to 10 engineering systems         Yes; Up to 16 simultaneously (in total across all ES clients)         No
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects         Test commission (Team Engineering)         Status block         Single step         Number of breakpoints	64         Yes         10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH         5 000         4 000         1 000         480         Yes; Parallel online access possible for up to 10 engineering systems         Yes; Up to 16 simultaneously (in total across all ES clients)         No
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects         Test commission (Team Engineering)         Status block         Single step         Number of breakpoints	64         Yes         10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH         5 000         4 000         1 000         4 80         Yes; Parallel online access possible for up to 10 engineering systems         Yes; Up to 16 simultaneously (in total across all ES clients)         No         20
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects         Test commission (Team Engineering)         Status block         Single step         Number of breakpoints         Status/control         • Status/control variable	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times,
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects         Test commission (Team Engineering)         Status block         Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times,
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects <b>Test commissioning functions</b> Joint commission (Team Engineering)         Status block         Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.	64         Yes         10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH         5 000         4 000         1 000         480         Yes; Parallel online access possible for up to 10 engineering systems         Yes; Up to 16 simultaneously (in total across all ES clients)         No         20         Yes; without fail-safe         inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects         Test commissioning functions         Joint commission (Team Engineering)         Status block         Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         — of which status variables, max.	64         Yes         10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH         5 000         4 000         1 000         480         Yes; Parallel online access possible for up to 10 engineering systems         Yes; Up to 16 simultaneously (in total across all ES clients)         No         20         Yes; without fail-safe         inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters         200; per job
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects <b>Test commission (Team Engineering)</b> Status block         Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         — of which status variables, max.         — of which control variables, max.	64         Yes         10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH         5 000         4 000         1 000         4 80         Yes; Parallel online access possible for up to 10 engineering systems         Yes; Up to 16 simultaneously (in total across all ES clients)         No         20         Yes; without fail-safe         inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters         200; per job         200; per job         Yes; without fail-safe
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects <b>Test commissioning functions</b> Joint commission (Team Engineering)         Status block         Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         — of which status variables, max.         — of which control variables, max.	64         Yes         10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH         5 000         4 000         1 000         4 80         Yes; Parallel online access possible for up to 10 engineering systems         Yes; Up to 16 simultaneously (in total across all ES clients)         No         20         Yes; without fail-safe         inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters         200; per job         200; per job
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects         Test commissioning functions         Joint commission (Team Engineering)         Status block         Single step         Number of variables, max.         - of which status variables, max.         - of which status variables, max.         - of which control variables, max.         Forcing         • Forcing         • Forcing         • Forcing         • Number of variables, max.	64         Yes         10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH         5 000         4 000         1 000         4 80         Yes; Parallel online access possible for up to 10 engineering systems         Yes; Up to 16 simultaneously (in total across all ES clients)         No         20         Yes; without fail-safe         inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters         200; per job         200; per job         Yes; without fail-safe
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects <b>Test commissioning functions</b> Joint commission (Team Engineering)         Status block         Single step         Number of variable         • Variables         • Number of variables, max.         — of which status variables, max.         — of which control variables, max.         — of which control variables, max.         Forcing         • Forcing         • Forcing         • Forcing	64         Yes         10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH         5 000         4 000         1 000         480         Yes; Parallel online access possible for up to 10 engineering systems         Yes; Up to 16 simultaneously (in total across all ES clients)         No         20         Yes; without fail-safe         inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters         200; per job         200; per job         Yes; without fail-safe         inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters         200; per job         Yes; without fail-safe         peripheral inputs/outputs (without fail-safe)
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects         Test commissioning functions         Joint commission (Team Engineering)         Status block         Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         — of which status variables, max.         — of which control variables, max.         — of which control variables, max.         Forcing         • Forcing         • Forcing         • Forcing         • Number of variables, max.         Diagnostic buffer         • present	64         Yes         10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH         5 000         4 000         1 000         480         Yes; Parallel online access possible for up to 10 engineering systems         Yes; Up to 16 simultaneously (in total across all ES clients)         No         20         Yes; without fail-safe         inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters         200; per job         Yes; without fail-safe         peripheral inputs/outputs (without fail-safe)         200; Yes; without fail-safe         Peripheral inputs/outputs (without fail-safe)         200         Yes
S7 message functions         Number of login stations for message functions, max.         Program alarms         Number of configurable program messages, max.         Number of loadable program messages in RUN, max.         Number of simultaneously active program alarms         • Number of program alarms         • Number of alarms for system diagnostics         • Number of alarms for motion technology objects         Test commissioning functions         Joint commission (Team Engineering)         Status block         Single step         Number of variables, max.         - of which status variables, max.         - of which status variables, max.         - of which control variables, max.         - of which status variables, max.         - of which status variables, max.         - Dof which status variables, max.         - Number of variables, max.         - Dof which control variables, max.         - Dof which control variables, max.         - Dof which control variables, max.         - Number of variables, max.         - Dof which control variables, max.         - Dof which control variables, max.         - Dof which status variables, max.         - Dof which status variables, max.         - Dof which status variables, max.	64         Yes         10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH         5 000         4 000         1 000         480         Yes; Parallel online access possible for up to 10 engineering systems         Yes; Up to 16 simultaneously (in total across all ES clients)         No         20         Yes; without fail-safe         inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters         200; per job         Yes; without fail-safe         inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters         200; per job         Yes; without fail-safe         200; per job         200; per job         200; per job

Traces	
Number of configurable Traces	8; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	
Diagnostics indication LED	
RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
<ul> <li>Connection display LINK TX/RX</li> </ul>	Yes
Supported technology objects	
Motion Control	Yes; Note: The number of technology objects affects the cycle time of the PLC
<ul> <li>Number of available Motion Control resources for technology objects</li> </ul>	program; selection guide via the TIA Selection Tool 15 360
Required Motion Control resources	
— per speed-controlled axis	40
— per positioning axis	80
— per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
Positioning axis	
<ul> <li>Number of positioning axes at motion control cycle of 4 ms (typical value)</li> </ul>	140
<ul> <li>— Number of positioning axes at motion control cycle of 8 ms (typical value)</li> </ul>	192
Controller	
PID_Compact	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Standards, approvals, certificates	
Ecological footprint	
environmental product declaration	Yes
Global warming potential	
<ul> <li>global warming potential, (total) [CO2 eq]</li> </ul>	570 kg
— global warming potential, (during production) [CO2 eq]	96.9 kg
— global warming potential, (during operation) [CO2 eq]	483 kg
<ul> <li>global warming potential, (after end of life cycle)</li> <li>[CO2 eq]</li> </ul>	-9.97 kg
Highest safety class achievable in safety mode	
<ul> <li>Performance level according to ISO 13849-1</li> </ul>	PLe
• SIL acc. to IEC 61508	SIL 3
Probability of failure (for service life of 20 years and repair time	e of 100 hours)
— Low demand mode: PFDavg in accordance with SIL3	< 2.00E-05
<ul> <li>High demand/continuous mode: PFH in accordance with SIL3</li> </ul>	< 1.00E-09
Ambient conditions	
Ambient temperature during operation	
horizontal installation, min.	0 °C
<ul> <li>horizontal installation, max.</li> </ul>	60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off
<ul> <li>vertical installation, min.</li> </ul>	0 °C
<ul> <li>vertical installation, max.</li> </ul>	40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
<ul> <li>Installation altitude above sea level, max.</li> </ul>	5 000 m

Ambient air temperature-barometric pressure-altitude	Restrictions for installation altitudes > 2 000 m, see entry ID: 109763260
Relative humidity     With condensation, tested in accordance with IEC 60068-	100 %; RH incl. condensation/frost (no commissioning under condensation
2-38, max.	conditions)
Resistance	
Coolants and lubricants	
<ul> <li>Resistant to commercially available coolants and lubricants</li> </ul>	Yes; Incl. diesel and oil droplets in the air
Use in stationary industrial systems	
<ul> <li>— to biologically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request
<ul> <li>— to chemically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *
<ul> <li>— to mechanically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3S4 incl. sand, dust, *
Use on ships/at sea	
<ul> <li>— to biologically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6B2 mold and fungal spores (excluding fauna); Class 6B3 on request
<ul> <li>— to chemically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *
<ul> <li>— to mechanically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6S3 incl. sand, dust; *
Usage in industrial process technology	
<ul> <li>Against chemically active substances acc. to EN 60654-4</li> </ul>	Yes; Class 3 (excluding trichlorethylene)
<ul> <li>Environmental conditions for process, measuring and control systems acc. to ANSI/ISA-71.04</li> </ul>	Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil)
Remark	
<ul> <li>— Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04</li> </ul>	* The supplied plug covers must remain in place over the unused interfaces during operation!
Conformal coating	
<ul> <li>Coatings for printed circuit board assemblies acc. to EN 61086</li> </ul>	Yes; Class 2 for high reliability
<ul> <li>Protection against fouling acc. to EN 60664-3</li> </ul>	Yes; Type 1 protection
<ul> <li>Military testing according to MIL-I-46058C, Amendment 7</li> </ul>	Yes; Discoloration of coating possible during service life
<ul> <li>Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC- CC-830A</li> </ul>	Yes; Conformal coating, Class A
configuration / header	
configuration / programming / header	
Programming language	
— LAD	Yes; incl. failsafe
— FBD	Yes; incl. failsafe
— STL	Yes
- SCL	Yes
— GRAPH	Yes
Know-how protection	
User program protection/password protection	Yes
Copy protection	Yes
Block protection	Yes
Access protection	N .
Password for display	Yes
Protection level: Write protection	Yes; Specific write protection both for Standard and for Failsafe
Protection level: Read/write protection	Yes
Protection level: Write protection for Failsafe     Protection level: Complete protection	Yes
Protection level: Complete protection	Yes
programming / cycle time monitoring / header  o lower limit	adjustable minimum cycle time
upper limit	adjustable minimum cycle time
Dimensions	
Width	175 mm
Height	175 mm 147 mm
Depth	129 mm
r	

eight, approx.		1 9	988 g		
ssifications			U C		
				Version	Classification
			eClass	14	27-24-22-07
			eClass	12	27-24-22-07
			eClass	9.1	27-24-22-07
			eClass	9	27-24-22-07
			eClass	8	27-24-22-07
			eClass	7.1	27-24-22-07
			eClass	6	27-24-22-07
			ETIM	9	EC000236
			ETIM	8	EC000236
			ETIM	7	EC000236
			IDEA	4	3565
			UNSPSC	15	32-15-17-05
Seneral Product Appro	CE	Manufacturer Declara tion	UK CA	መ	
	EG-Konf.				
				UL	TÜV
EMV		For use in hazardo		uL Functional Saftey	TÜV Marine / Shipping
emv KC	RCM	For use in hazardo		Functional Saftey	
	RCM	IECE×		UL Functional Saftey	Marine / Shipping
KC	RCM	IECE×		UL Functional Saftey	Marine / Shipping