



Figure similar

SIPLUS S7-1200 CM 1242-5 T1 rail based on 6GK7242-5DX30-0XE0 with conformal coating, -25...+55 °C, OT1 with ST1/2 (+70 °C für 10 minutes), communications module CM 1242-5, for connecting S7-1200 to PROFIBUS as DP slave module

transfer rate	
transfer rate	
• at the 1st interface / according to PROFIBUS	9.6 kbit/s ... 12 Mbit/s
interfaces	
number of interfaces / according to Industrial Ethernet	0
number of electrical connections	
• at the 1st interface / according to PROFIBUS	1
• for power supply	0
type of electrical connection	
• at the 1st interface / according to PROFIBUS	9-pin Sub-D socket (RS485)
supply voltage, current consumption, power loss	
type of voltage / of the supply voltage	DC
supply voltage / 1 / from backplane bus	5 V
consumed current	
• from backplane bus / at DC / at 5 V / typical	0.15 A
power loss [W]	0.75 W
ambient conditions	
ambient temperature	
• during operation	-25 ... +55 °C
• during storage	-40 ... +70 °C
• during transport	-40 ... +70 °C
• note	+70 °C for 10 min (OT1, ST1/ST2 according to EN 50155)
installation altitude / at height above sea level / maximum	2000 m
ambient condition / relating to ambient temperature - air pressure - installation altitude	Tmin ... Tmax at 1 140 hPa ... 795 hPa (-1 000 m ... +2 000 m)
relative humidity	
• with condensation / according to IEC 60068-2-38 / maximum	100 %; RH including condensation/frost (no commissioning when condensation is present), horizontal installation
chemical resistance / to commercially available cooling lubricants	Yes; incl. airborne diesel and oil droplets
resistance to biologically active substances	
• conformity according to EN 60721-3-3	Yes; Class 3B2 mold and fungal spores (excluding fauna), Class 3B3 on request
• conformity according to EN 60721-3-5	Yes; Class 5B2 mold and fungal spores (excluding fauna), Class 5B3 on request
resistance to chemically active substances	
• conformity according to EN 60721-3-3	Yes; Class 3C4 (RH < 75 %) incl. salt spray in accordance with EN 60068-2-52 (Severity 3). The supplied plug covers must remain in place on the unused interfaces during operation.
• conformity according to EN 60721-3-5	Yes; Class 5C3 (RH < 75%) including salt spray acc. to EN 60068-2-52 (Severity level 3). The supplied plug covers must remain in place over the unused interfaces during operation!

resistance to mechanically active substances	
<ul style="list-style-type: none"> conformity according to EN 60721-3-3 	Yes; Class 3S4 incl. sand, dust. The supplied plug covers must remain in place over the unused interfaces during operation.
<ul style="list-style-type: none"> conformity according to EN 60721-3-5 	Yes; Class 5S3 incl. sand, dust. The supplied plug covers must remain in place over the unused interfaces during operation!
coating / for equipped printed circuit board / according to EN 61086	Yes; Class 2 for high availability
type of coating / protection against pollution according to EN 60664-3	Yes; Protection of the type 1
type of coating / for electronic devices in railway applications according to EN 50155	Yes; Protective coating of the Class PC2 according to EN 50155:2017
type of test / of the coating / according to MIL-I-46058C	Yes; Coating discoloration during service life possible
product conformity / of the coating / Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC-CC-830A	Yes; Conformal coating, class A
protection class IP	IP20
design, dimensions and weights	
module format	Compact module S7-1200 single width
width	30 mm
height	100 mm
depth	75 mm
net weight	0.115 kg
fastening method	
<ul style="list-style-type: none"> 35 mm DIN-rail mounting 	Yes
<ul style="list-style-type: none"> S7-300 rail mounting 	No
<ul style="list-style-type: none"> wall mounting 	Yes
product features, product functions, product components / general	
number of units	
<ul style="list-style-type: none"> per CPU / maximum 	3
performance data / PROFIBUS DP	
service / as DP slave	
<ul style="list-style-type: none"> DPV0 	Yes
<ul style="list-style-type: none"> DPV1 	Yes
data volume	
<ul style="list-style-type: none"> of the address range of the inputs / as DP slave / total 	240 byte
performance data / telecontrol	
protocol / is supported	
<ul style="list-style-type: none"> TCP/IP 	No
product functions / management, configuration, engineering	
configuration software	
<ul style="list-style-type: none"> required 	#NO_DATA
product functions / position detection	
certificate of suitability / railway application in accordance with EN 50121-3-2	Yes; EMC for railway vehicles
certificate of suitability / railway application in accordance with EN 50121-4	Yes
certificate of suitability / railway application in accordance with EN 50124-1	Yes; Railway applications - Overvoltage category OV2 pollution degree PD2 rated impulse voltage UNi = 0.5 kVUNm = DC 24
certificate of suitability / railway application in accordance with EN 50125-1	Yes; Railway vehicles - See ambient conditions
certificate of suitability / railway application in accordance with EN 50125-2	Yes; Fixed-electrical installations - see ambient conditions
certificate of suitability / railway application in accordance with EN 50125-3	Yes; Signal and telecommunications equipment - see Ambient conditions vibrations and shocks: Application point outside the rails (distance 1 m to 3 m from rail)
certificate of suitability / railway application in accordance with EN 50155	Yes; Railway vehicles - temperature class OT1, ST1/ST2, horizontal mounting position
certificate of suitability / railway application in accordance with EN 61373	Yes; Railway vehicles - Vibrations and shocks Category 1 Class A/B
certificate of suitability / fire protection in accordance with EN 45545-2	Yes; Railway vehicles - for proof, see Service & Support
standards, specifications, approvals	
reference code	
<ul style="list-style-type: none"> according to IEC 81346-2:2019 	KEC
further information / internet links	





internet link	<ul style="list-style-type: none"> • to website: Selection guide for cables and connectors • to web page: selection aid TIA Selection Tool • to website: Industrial communication • to web page: SiePortal • to website: Image database • to website: CAx-Download-Manager • to website: Industry Online Support
---------------	---

<https://support.industry.siemens.com/cs/ww/en/view/109766358>
<https://www.siemens.com/tstcloud>
<https://www.siemens.com/simatic-net>
<https://sieportal.siemens.com/>
<https://www.automation.siemens.com/bilddb>
<https://siemens.com/cax>
<https://support.industry.siemens.com>

security information

security information	<p>Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)</p>
----------------------	---

Approvals / Certificates

General Product Approval		EMV
Miscellaneous	Manufacturer Declaration	   

Railway
Confirmation

last modified:

4/3/2025 