SIEMENS

Data sheet

6GK7542-5DX00-0XE0

product type designation



CM 1542-5

communications module CM 1542-5 for connection of S7-1500 to PROFIBUS DP, DPV1 master or DP slave, S7 and PG/OP communication, data record routing, time-of-day synchronization, diagnostic

transfer rate	
transfer rate	
 at the 1st interface / according to PROFIBUS 	9.6 kbit/s 12 Mbit/s
interfaces	
number of interfaces / according to Industrial Ethernet	0
number of electrical connections	
 at the 1st interface / according to PROFIBUS 	1
type of electrical connection	
 at the 1st interface / according to PROFIBUS 	9-pin Sub-D socket (RS485)
supply voltage, current consumption, power loss	
type of voltage / of the supply voltage	DC
supply voltage / 1 / from backplane bus	15 V
relative symmetrical tolerance / at DC	
• at 15 V	3 %
consumed current	
• from backplane bus / at DC / at 15 V / typical	0.2 A
power loss [W]	3 W
ambient conditions	
ambient temperature	
 for vertical installation / during operation 	0 40 °C
 for horizontally arranged busbars / during operation 	0 60 °C
during storage	-40 +70 °C
during transport	-40 +70 °C
relative humidity	
• at 25 °C / without condensation / during operation / maximum	95 %
protection class IP	IP20
design, dimensions and weights	
module format	Compact module S7-1500 single width
width	35 mm
height	142 mm
depth	129 mm
net weight	0.4 kg
fastening method	
S7-1500 rail mounting	Yes
product features, product functions, product components / general	
number of units	
• per CPU / maximum	8
• note	depending on CPU type

performance data / open communication	
number of possible connections / for open communication / by	30
means of SEND/RECEIVE blocks / maximum	
data volume	
 as user data per connection / for open communication / by means of SEND/RECEIVE blocks / maximum 	240 byte
performance data / PROFIBUS DP	
service / as DP master	
• DPV1	Yes
number of DP slaves	100
• on DP master / operable	125
data volume	
of the address range of the inputs / as DP master / total	8192 byte
• of the address range of the outputs / as DP master / total	8192 byte
 of the address range of the inputs / per DP slave 	244 byte
 of the address range of the outputs / per DP slave 	244 byte
service / as DP slave	
• DPV0	Yes
• DPV1	Yes
data volume	
• of the address range of the inputs / as DP slave / total	240 byte
of the address range of the outputs / as DP slave / total	240 byte
performance data / S7 communication	
number of possible connections / for S7 communication	
maximum	48; depending on the system upper limit
performance data / multi-protocol mode	
number of active connections / with multi-protocol mode	48
performance data / telecontrol	
protocol / is supported	
• TCP/IP	No
product functions / management, configuration, engineering	
configuration software	
• required	STEP 7 Professional V12 (TIA Portal) or higher
identification & maintenance function	Voc
18M0 - device-specific information 18M1 - higher level designation designation.	Yes
I&M1 - higher level designation/location designation product functions / diagnostics	Yes
product functions / diagnostics	Vec. via S7 1500 CDI I
product function / web-based diagnostics product functions / time	Yes; via S7-1500 CPU
	Yes
product function / pass on time synchronization standards, specifications, approvals	1 03
reference code	
according to IEC 81346-2:2019	KEC
standards, specifications, approvals / Environmental Product D	
Environmental Product Declaration Yes	
global warming potential [CO2 eq]	160
total	115.52 kg
during manufacturing	21.24 kg
during manufacturing during operation	93.93 kg
after end of life	0.35 kg
further information / internet links	
further information / internet links internet link	
internet link	https://www.siemens.com/tstcloud
	https://www.siemens.com/tstcloud https://www.siemens.com/simatic-net
internet link • to web page: selection aid TIA Selection Tool • to website: Industrial communication	https://www.siemens.com/tstcloud https://www.siemens.com/simatic-net https://sieportal.siemens.com/
internet link • to web page: selection aid TIA Selection Tool	https://www.siemens.com/simatic-net
internet link • to web page: selection aid TIA Selection Tool • to website: Industrial communication • to web page: SiePortal	https://www.siemens.com/simatic-net https://sieportal.siemens.com/
internet link • to web page: selection aid TIA Selection Tool • to website: Industrial communication • to web page: SiePortal • to website: Image database	https://www.siemens.com/simatic-net https://sieportal.siemens.com/ https://www.automation.siemens.com/bilddb
internet link • to web page: selection aid TIA Selection Tool • to website: Industrial communication • to web page: SiePortal • to website: Image database • to website: CAx-Download-Manager	https://www.siemens.com/simatic-net https://sieportal.siemens.com/ https://www.automation.siemens.com/bilddb https://siemens.com/cax
internet link • to web page: selection aid TIA Selection Tool • to website: Industrial communication • to web page: SiePortal • to website: Image database • to website: CAx-Download-Manager • to website: Industry Online Support	https://www.siemens.com/simatic-net https://sieportal.siemens.com/ https://www.automation.siemens.com/bilddb https://siemens.com/cax

In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)

Approvals / Certificates

General Product Approval



Declaration of Conformity









General Product Ap-

For use in hazardous locations

Environment







<u>FM</u>

CCC-Ex

Confirmation

Environment



last modified:

2/18/2025

